



Fraunhofer

TESTED[®] DEVICE

HIWIN GmbH
Linear module HM080B
Report No. HI 2504-1621

DUPLICATE

Statement of
Qualification

Single product
Particle Emission
in Cleanroom
(atmospheric)

Customer	HIWIN GmbH Brücklesbünd 1 77654 Offenburg Germany
Tested product	
Category:	Automation Components
Subcategory:	Linear Units
Product name:	Linear module HM080B with profile rail QHH20 (manufacturing date: 3/2025; color: aluminium silver; type: HM080B190N1000S000NNNRHW08G0805-X; weight: 22 kg; article number: 80158125; serial number: HSN0000039085)

Random sampling of particle emissions (airborne) at representative sites in cleanroom under atmospheric conditions

Standards/guidelines:	ISO 14644-1, -14 The norms stated generally refer to the version valid at the time of the tests.
Test equipment:	Optical particle counter: LasAir II 110 and LasAir III 110 with measuring ranges $\geq 0.1\text{ }\mu\text{m}$, $\geq 0.2\text{ }\mu\text{m}$, $\geq 0.3\text{ }\mu\text{m}$, $\geq 0.5\text{ }\mu\text{m}$, $\geq 1.0\text{ }\mu\text{m}$ and $\geq 5.0\text{ }\mu\text{m}$
Test environment parameters:	<ul style="list-style-type: none">Cleanroom Air Cleanliness Class (according to ISO 14644-1):..... ISO 1Airflow velocity:.....0.45 m/sAirflow pattern:..... vertical laminar flowRoom temperature:22 °C ± 0.5 °CRelative humidity: 45 % ± 5 %
Test procedure parameters:	<ul style="list-style-type: none">Installation position: horizontal, slide at the topTravel length:..... s = 1000 mmAttached payload:noneSuction parameters:<ul style="list-style-type: none">– Volume flow: Q = 176l/min per four connectorsParameter Set 1:.....$v_1 = 0.5\text{ m/s}$; $a_1 = 1.0\text{ m/s}^2$; without suctionParameter Set 2:.....$v_2 = 1.0\text{ m/s}$; $a_2 = 2.0\text{ m/s}^2$; without suctionParameter Set 3:.....$v_3 = 1.5\text{ m/s}$; $a_3 = 3.0\text{ m/s}^2$; without suctionParameter Set 4:.....$v_1 = 0.5\text{ m/s}$; $a_1 = 1.0\text{ m/s}^2$; with suctionParameter Set 5:.....$v_2 = 1.0\text{ m/s}$; $a_2 = 2.0\text{ m/s}^2$; with suctionParameter Set 6:.....$v_3 = 1.5\text{ m/s}$; $a_3 = 3.0\text{ m/s}^2$; with suction

Test result / Classification

The linear module HM080B with profile rail QHH20 is suitable for use under the specified test parameters (room temperature: 22 °C ± 0.5 °C; relative humidity: 45 % ± 5 %) in cleanrooms of the following Air Cleanliness Classes according to ISO 14644-1:

Test parameter(s)	Air Cleanliness Class
$v_1 = 0.5\text{ m/s}$; $a_1 = 1.0\text{ m/s}^2$; without suction	5
$v_2 = 1.0\text{ m/s}$; $a_2 = 2.0\text{ m/s}^2$; without suction	6
$v_3 = 1.5\text{ m/s}$; $a_3 = 3.0\text{ m/s}^2$; without suction	6
$v_1 = 0.5\text{ m/s}$; $a_1 = 1.0\text{ m/s}^2$; with suction	2
$v_2 = 1.0\text{ m/s}$; $a_2 = 2.0\text{ m/s}^2$; with suction	4
$v_3 = 1.5\text{ m/s}$; $a_3 = 3.0\text{ m/s}^2$; with suction	5
Overall result	6

Please note: Transport damages, incorrect installation, oil leakage, aging behavior, corrosion etc. can influence the test result.

The measuring devices used for the qualification tests are calibrated at regular intervals; their results can be traced back to national and international standards. In cases where no national standards exist, the test procedure implemented complies with the technical regulations and norms applicable at the time of the test. The relevant documentation can be viewed on request at any time.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Fraunhofer Institute for Manufacturing Engineering and Automation IPA	HI 2504-1621 Report No. first document	Stuttgart, May 28, 2025 Place, date of first document issued
Business unit Testing and Certification	-- Report No. current document	-- Place, current date
Nobelstrasse 12 70569 Stuttgart Germany	on behalf of Dr.-Ing. Frank Bürger, head of business unit Testing and Certification	