



valid until: December 6, 2029

Fraunhofer

TESTED[®] DEVICE

Parteco S.r.l.
Parteco PST and CIS system
Report No. PA 2410-1571

Single product Particle Emission in Cleanroom (atmospheric)

Qualification Certificate

This is to certify that the product mentioned above, provided by

Parteco S.r.l.
Lissone, Italy

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number PA 2410-1571.

The Parteco PST and CIS system (color ceiling panel: RAL9010) was assessed in compliance with ISO 14644-14. When operated under the specified test conditions (room temperature: 22 °C ± 0.5 °C; relative humidity: 45 % ± 5 %), it is suitable for use in cleanrooms fulfilling the specifications of the following Air Cleanliness Classes according to ISO 14644-1:

Test parameter(s)	Air Cleanliness Class
Structure-borne noise = approx. 50Hz Inside measurement	2
Structure-borne noise = approx. 50Hz Outside measurement	1
Overall result	2

Please note: Transport damages, incorrect installation, aging behavior, corrosion etc. can influence the test result.

PA 2410-1571
Report No. first document

Stuttgart, December 6, 2024
Place, date of first document issued

--
Report No. current document

--
Place, current date

on behalf of 
Dr.-Ing. Frank Bürger, Project Manager Fraunhofer IPA

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.