

Tarkett France Report No. TA 2404-1519

Cleanroom® Suitable Materials

Acczent Platinium (smooth) Riboflavin Test: excellent

FLOORING & COATING

Single product Riboflavin Test

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under

www.tested-device.com

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Qualification Certificate

We hereby certify that the material stated above, provided by

Tarkett France Sedan, France

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number TA 2404-1519.

The examination of cleanability of Acczent Platinium (color: gray/flakes) was investigated according to VDMA information sheet. The following test result could be provided:

| Material tested | Classification |
|-------------------------------|----------------|
| Acczent Platinium (smooth) | excellent |

TA 2404-1519 Report No. first document

Report No. current document

Stuttgart, June 6, 2025 Place, date of first document issued

Place, date of first document issued

Place, current date on behalf of D. B. Frank Bürger, Project manager Fraunhofer IPA

