



# Cleanroom<sup>®</sup> Suitable Materials

CIN  
Report No. CI 2403-1510

C-FLOOR E245 WB  
Biological Resistance: good

## FLOORING & COATING

### Single product Biological Resistance

### Qualification Certificate

We hereby certify that the material stated above, provided by

CIN - Corporação Industrial do Norte, S.A.  
Maia, Portugal

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number CI 2403-1510.

The biological resistance of C-FLOOR E245 WB (color: RAL 9010) regarding to growth intensity was investigated in accordance with ISO 846 and classified with the following result:

Biological resistance	Growth intensity	Classification
Procedure A (resistance to fungi)	0	excellent
Procedure C (resistance to bacteria)	1	good
<b>Overall result</b>	<b>good</b>	

The classification is based on a worst-case consideration of the Procedures A and C.

CI 2403-1510  
Report No. first document

Stuttgart, June 7, 2024  
Place, date of first document issued

--  
Report No. current document

--  
Place, current date

on behalf of   
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under [www.tested-device.com](http://www.tested-device.com).

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.