



Fraunhofer

TESTED[®] DEVICE

Rite-Hite Corporation
LITESPEED CLEANROOM
Report No. RI 2108-1247

Single product
Hygienic Design

Qualification Certificate

This is to certify that the product mentioned above, provided by

**Rite-Hite Material Handling
Equipment (Kunshan) Co., Ltd.**
Kunshan Jiangsu , China

has been awarded a Fraunhofer certificate TESTED DEVICE
bearing the report number RI 2108-1247.

The LITESPEED CLEANROOM High Performance Door (color:
white) is principally suitable for use in hygienic areas up to the
following GMP Class according to EU GMP Annex 1:

Suitability
up to GMP Class C

However, this recommendation only pertains to the operating
utility when in a resting state. An overall assessment of the door
LITESPEED CLEANROOM can only be made after its installation in
the production line.

This document only
applies to the named
product in its original state
and is valid for a period of
5 years from the date the
first document was issued.
The document can be
verified under
www.tested-device.com.

Detailed information and
parameters of the test
environment can be found
in the Fraunhofer IPA test
report.

RI 2108-1247
Report No. first document

Stuttgart, March 3, 2022
Place, date of first document issued

--
Report No. current document

--
Place, current date

on behalf of 
Dr.-Ing. Frank Bürger, Project Manager Fraunhofer IPA