



Tremco CPG Europe
Report No. TR 2501-1581

Cleanroom[®] Suitable Materials

Flowcoat SF41LE
Outgassing Behavior VOC/SVOC
ISO-ACC_m Class < -9.6 / -5.5

FLOORING & COATING

Single product
Outgassing Behavior
VOC/SVOC

DUPLICATE

Qualification Certificate

We hereby certify that the material stated above, provided by
Tremco CPG Europe
Bodenwoehr, Germany
has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number TR 2501-1581.

The outgassing behavior of Flowcoat SF41LE (color: 280, mid gray) at the stated temperature was investigated according to VDI 2083 Part 17, ISO 14644-15 and ISO 16000-25. Based on the outgassing rates determined for the specific surfaces, the following material classification was made for the corresponding Contaminant Category:

Contaminant Category (x)	SER _a ¹⁾ 23 °C [g/m²s]	ISO-ACC _m Class (x) based on 23 °C
VOC	< 2.8 x 10 ⁻¹⁰	< -9.6
SVOC	3.4 x 10 ⁻⁶	-5.5
Sum of VOC and SVOC	3.4 x 10 ⁻⁶	--
Refractories ²⁾	2.3 x 10 ⁻⁸	--
Siloxanes ³⁾	7.5 x 10 ⁻¹⁰	--

SER: Area-specific emission rate
¹⁾ The emission rate is calculated using the detected mass based on the response of the standard, the analyzed sample surface area or number of samples and the sampling duration.
²⁾ Refractories are compounds containing elements other than C, H and O (e.g.: S, P, N...).
³⁾ Siloxanes and other Si-containing organic substances. Siloxanes also count as refractories.

TR 2501-1581
Report No. first document
--
Report No. current document

Stuttgart, May 22, 2025
Place, date of first document issued
--
Place, current date
on behalf of
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.