



Fraunhofer

TESTED[®] DEVICE

Up-Shine Lighting
Cleanroom LED Panel (60120)
Report No. UP 2505-1626

DUPLICATE

Statement of
Qualification

Single product
Particle Emission
in Cleanroom
(atmospheric)

Customer

Up-Shine Lighting Co., Limited
Fuyong Street
518103 Shenzhen
China

Tested product

Category:Cleanroom Facilities

Subcategory:Lighting Systems

Product name:Cleanroom LED Panel Light (60120)
(manufacturing date: 2/2025; color: white; article code: CK22B-60120-72W-DA6; batch number: CK22B; charge number: 000000)

Random sampling of particle emissions (airborne) at representative sites in cleanroom under atmospheric conditions

Standards/guidelines:ISO 14644-1, -14
The norms stated generally refer to the version valid at the time of the tests.

Test equipment:Optical particle counter:
LasAir II 110 and LasAir III 110 with measuring ranges $\geq 0.1\text{ }\mu\text{m}$, $\geq 0.2\text{ }\mu\text{m}$, $\geq 0.3\text{ }\mu\text{m}$, $\geq 0.5\text{ }\mu\text{m}$, $\geq 1.0\text{ }\mu\text{m}$ and $\geq 5.0\text{ }\mu\text{m}$

Test environment parameters:

- Cleanroom Air Cleanliness Class (according to ISO 14644-1):..... ISO 1
- Airflow velocity:.....0.45 m/s
- Airflow pattern:..... vertical laminar flow
- Room temperature:22 °C ± 0.5 °C
- Relative humidity: 45 % ± 5 %

Test procedure parameters:The luminaire was subjected to stress as follows:

- Structure-borne noise: approx. 50 Hz
- Oscillation velocity (Ø):.....v = 4.1260 mm/s
- Oscillation acceleration (Ø):.....a = 1.6920 m/s²
- Deflection of the system (Ø):..... s = 0.0645 mm

Test result / Classification

The Cleanroom LED Panel Light (60120) is suitable for use under the specified test parameters (room temperature: 22 °C ± 0.5 °C; relative humidity: 45 % ± 5 %) in cleanrooms of the following Air Cleanliness Class according to ISO 14644-1:

Test parameter(s)	Air Cleanlines Class
Structure-borne noise = approx. 50 Hz	1
Overall result	

It should be noted that cleanrooms of class 1 to 5 according to ISO 14644-1 have a higher filter occupancy, which may restrict the use of panel lighting systems. Cleanrooms with a horizontal displacement flow form an exception to this.

The test result may be affected by the surrounding ceiling system, in particular the material pairing between lights and ceiling frames, as well as other mounting accessories. Particle emission behavior should be reassessed in each assembly situation.

Please note: Transport damages, incorrect installation, aging behavior, corrosion etc. can influence the test result.

The measuring devices used for the qualification tests are calibrated at regular intervals; their results can be traced back to national and international standards. In cases where no national standards exist, the test procedure implemented complies with the technical regulations and norms applicable at the time of the test. The relevant documentation can be viewed on request at any time.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Fraunhofer Institute for Manufacturing Engineering and Automation IPA

UP 2505-1626

Stuttgart, June 6, 2025

Business unit Testing and Certification

Report No. first document

Place, date of first document issued

on behalf of

Report No. current document

Place, current date

Dr.-Ing. Frank Bürger, head of business unit Testing and Certification