



Gradus Ltd.
Report No. GR 2511-1688
Cleanroom (atmospheric)

FLOORING & COATING

Single product Chemical Resistance

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Cleanroom[®] Suitable Materials

SureProtect Pure
Chemical Resistance:
excellent

DUPPLICATE

Qualification Certificate

We hereby certify that the material stated above, provided by

Gradus Ltd.
Macclesfield, United Kingdom

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number GR 2511-1688.

The chemical resistance tests on SureProtect Pure PVC-u Hygienic Sheet SPP25 (color: satin white) are performed in accordance with ISO 2812-1. Therefore the damages according to ISO 4628-1 and VDI 2083 Part 17 have been transferred to the following classification:

Chemicals	Chemical resistance	Chemicals	Chemical resistance
Formalin 37 %	excellent	Phosphoric acid 30 %	excellent
Ammoniac 25 %	excellent	Hydrochlorid acid 5 %	excellent
Isopropanol 100 %	excellent	Hydrogen peroxide 10 %	excellent
Sulfuric acid 5 %	excellent	Sodium hydroxide 5 %	excellent
Peracetic acid 15 %	excellent	Sodium hypochlorite 5 %	excellent
Overall result	excellent		

GR 2511-1688
Report No. first document

--
Report No. current document

Stuttgart, December 16, 2025
Place, date of first document issued

--
Place, current date

on behalf of
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification