



# Fraunhofer

## TESTED<sup>®</sup> DEVICE

Cobetter & Xinkailai  
Pipeline SZ03VQC25C00011P  
**Report No. HA 2605-1772**

DUPLICATE

Statement of  
Qualification

Single product  
Particle Emission  
in Cleanroom  
(atmospheric)

# Statement of Qualification · Single product

**Customer**  
 Hangzhou Cobetter Filtration Equipment Co. Ltd.  
 Heshang New Materials Industry Part, Xiaoshan District  
 311300 Hangzhou. Zhejiang Provice  
 China

**Tested product**  
 Category: Energy Supply  
 Subcategory: Cable Systems  
 Product name: Water and gas pipeline SZ03VQC25C00011P  
 (manufacturing date: 3/12/2025; color: white; article number:  
 SZ03VQC25C00011P; batch number: 5N13174)

## Random sampling of particle emissions (airborne) at representative sites in cleanroom under atmospheric conditions

Standards/guidelines: ISO 14644-1, -14  
 The norms stated generally refer to the version valid at the time of the tests.

Test equipment: Optical particle counter:  
 LasAir II 110 and LasAir III 110 with measuring ranges  $\geq 0.1 \mu\text{m}$ ,  $\geq 0.2 \mu\text{m}$ ,  
 $\geq 0.3 \mu\text{m}$ ,  $\geq 0.5 \mu\text{m}$ ,  $\geq 1.0 \mu\text{m}$  and  $\geq 5.0 \mu\text{m}$

Test environment parameters:

- Cleanroom Air Cleanliness Class (according to ISO 14644-1):..... ISO 1
- Airflow velocity:.....0.45 m/s
- Airflow pattern:..... vertical laminar flow
- Room temperature: .....22 °C ± 0.5 °C
- Relative humidity: ..... 45 % ± 5 %

Test procedure parameters:

- Parameter Set 1:
  - Velocity:..... v = 250 mm/s
  - Acceleration: ..... a = 3000 mm/s<sup>2</sup>
  - Travel distance:..... s = 0.4 mm
- Parameter Set 2:
  - Velocity:.....not in operation
  - Acceleration: .....not in operation
  - Travel distance: .....not in operation

## Test result / Classification

The water and gas pipeline SZ03VQC25C00011P is suitable for use under the specified test parameters (room temperature: 22 °C ± 0.5 °C; relative humidity: 45 % ± 5 %) in cleanrooms of the following Air Cleanliness Classes according to ISO 14644-1:

Test parameter(s)	Air Cleanliness Class
s = 0.4 mm v = 250 mm/s a = 3000 mm/s <sup>2</sup>	1
Not in operation	1
<b>Overall result</b>	<b>1</b>

Please note: Transport damages, incorrect installation, aging behavior, corrosion, etc. can influence the test result.

The measuring devices used for the qualification tests are calibrated at regular intervals; their results can be traced back to national and international standards. In cases where no national standards exist, the test procedure implemented complies with the technical regulations and norms applicable at the time of the test. The relevant documentation can be viewed on request at any time.