



Fraunhofer

TESTED[®]
DEVICE

Fural Metalit Dipling
clip in window tile 625 x 625
Report No. FU 2605-1774

DUPLICATE

Statement of
Qualification

Single product
Hygienic Design

Customer	Fural Systeme in Metall GmbH Cumberlandstrasse 66 4810 Gmunden Austria
Tested product	
Category:	Cleanroom Facilities
Subcategory:	Wall/Ceiling/Floor/Door
Product name:	FK with sharp edges; quick suspension; with double grid (manufacturing date: 5/12/2026; color: lacquered in parzifal light white; dimensions: 625 x 625 mm; article number: 1000079)

Assessment of conformity to GMP regulations as well as to EHEDG conception and design recommendations

Standards/guidelines:	EU GMP Annex 1; EHEDG Doc. 8; DIN EN 1672-2; ISO 14159 The norms stated generally refer to the version valid at the time of the tests.
Assessment criteria:	- Materials utilized - Material pairings - Installed components - Geometries of components used - Joining methods - Detailed constructional solutions - Manufacturing processes - Surface coatings/coating systems The suitability of the operating utility for use in a GMP-conform manufacturing environment is ascertained on the basis of the assessment of these criteria with the aid of expert knowledge. The assessment focuses mainly on the avoidance of contamination as well as on the ability to clean and disinfect the operating utility.

Test result / Classification

The ceiling system FK with sharp edges; quick suspension; with double grid is principally suitable for use in hygienic areas up to the following GMP Class according to EU GMP Annex 1:

Suitability
Restricted to GMP Class A Unrestricted to GMP Class C

However, this recommendation only pertains to the operating utility when in a resting state. An overall assessment can only be made after its installation in the production environment.

The measuring devices used for the qualification tests are calibrated at regular intervals; their results can be traced back to national and international standards. In cases where no national standards exist, the test procedure implemented complies with the technical regulations and norms applicable at the time of the test. The relevant documentation can be viewed on request at any time.