



valid until: June 19, 2031

Fraunhofer

TESTED[®] DEVICE

Fural Metalit Dipling
clip-in system 625 x 625
Report No. FU 2605-1774

Single product
Particle Emission
in Cleanroom
(atmospheric)

Qualification Certificate

This is to certify that the product mentioned above, provided by

Fural Systeme in Metall GmbH
Gmunden, Austria

has been awarded a Fraunhofer certificate TESTED DEVICE
bearing the report number FU 2605-1774.

The ceiling system KQK with bevelled edges; nonius suspension;
without double grid (color: RAL 9010 powder-coated) was
assessed in compliance with ISO 14644-14. When operated
under the specified test conditions (room temperature:
 $22^{\circ}\text{C} \pm 0.5^{\circ}\text{C}$; relative humidity: $45\% \pm 5\%$), it is suitable for
use in cleanrooms fulfilling the specifications of the following Air
Cleanliness Class according to ISO 14644-1:

Test parameter(s)	Air Cleanliness Class
Structure-borne noise = approx. 50Hz	1
Overall result	

It should be noted that cleanrooms of Class 1 to 5 according to
ISO 14644-1 have a higher filter occupancy, which may restrict
the use of ceiling systems. Cleanrooms with a horizontal dis-
placement flow form an exception to this. The test result may be
affected by the surrounding ceiling system.
Please note: Transport damages, incorrect installation, aging
behavior, corrosion etc. can influence the test result.

FU 2605-1774
Report No. first document

Stuttgart, June 19, 2026
Place, date of first document issued

--
Report No. current document

--
Place, current date

on behalf of 
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification

This document only
applies to the named
product in its original state
and is valid for a period of
5 years from the date the
first document was issued.
The document can be
verified under
www.tested-device.com.

Detailed information and
parameters of the test
environment can be found
in the Fraunhofer IPA test
report.

The norms stated generally
refer to the version valid at
the time of the tests.