



valid until: June 19, 2031

Fraunhofer

TESTED[®] DEVICE

Fural Metalit Dipling
clip in window tile 625 x 625
Report No. FU 2605-1774

Single product
Hygienic Design

Qualification Certificate

This is to certify that the product mentioned above, provided by

Fural Systeme in Metall GmbH
Gmunden, Austria

has been awarded a Fraunhofer certificate TESTED DEVICE
bearing the report number FU 2605-1774.

The ceiling system FK with sharp edges; quick suspension; with
double grid (color: lacquered in parzifal light white) is principally
suitable for use in hygienic areas up to the following GMP Class
according to EU GMP Annex 1:

Suitability

Restricted to GMP Class A
Unrestricted to GMP Class C

However, this recommendation only pertains to the operating
utility when in a resting state. An overall assessment can only be
made after its installation in the production environment.

This document only
applies to the named
product in its original state
and is valid for a period of
5 years from the date the
first document was issued.
The document can be
verified under
www.tested-device.com.

Detailed information and
parameters of the test
environment can be found
in the Fraunhofer IPA test
report.

The norms stated generally
refer to the version valid at
the time of the tests.

FU 2605-1774
Report No. first document

Stuttgart, June 19, 2026
Place, date of first document issued

--
Report No. current document

--
Place, current date

on behalf of


Dr.-Ing. Frank Bürger, head of business unit Testing and Certification



Fraunhofer
IPA