



# Cleanroom<sup>®</sup> Suitable Materials

Trespa International B.V.  
Report No. TR 2604-1751  
Cleanroom (atmospheric)

TopLab ULTIM (black)  
Biological Resistance:  
good

## FLOORING & COATING

### Single product Biological Resistance

### Qualification Certificate

We hereby certify that the material stated above, provided by

Trespa International B.V.  
Weert, Netherlands

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number TR 2604-1751.

The biological resistance of the Trespa TopLab ULTIM (black) regarding to growth intensity was investigated in accordance with ISO 846 and classified with the following result:

| Biological resistance                   | Growth intensity | Classification |
|-----------------------------------------|------------------|----------------|
| Procedure A<br>(resistance to fungi)    | 1c               | good           |
| Procedure C<br>(resistance to bacteria) | 0                | excellent      |
| Overall result                          | good             |                |

The classification is based on a worst-case consideration of the Procedures A and C.

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under [www.tested-device.com](http://www.tested-device.com).

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

The norms stated generally refer to the version valid at the time of the tests.

TR 2604-1751  
Report No. first document  
--  
Report No. current document

Stuttgart, August 5, 2026  
Place, date of first document issued  
--  
Place, current date

on behalf of   
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification