



valid until: July 2, 2031

Fraunhofer

TESTED[®] DEVICE

Fortemix, s.r.o.
Fortelock ESD (graphite gray)
Report No. FO 2606-1781

Single product
Electrical
Resistance

Qualification Certificate

This is to certify that the product mentioned above, provided by

Fortemix, s.r.o.
Paskov, Czech Republic

has been awarded a Fraunhofer certificate TESTED DEVICE
bearing the report number FO 2606-1781.

The flooring Fortelock ESD (graphite gray) has been tested for its
resistance to ground and body voltage according to DIN EN IEC
61340-4-5 and qualified according to DIN EN IEC 61340-5-1. The
obtained data on resistance to ground and body voltage are within
the limits specified in DIN EN IEC 61340-5-1.

	Operating voltage [V]	Max. value [Ω]	Compliance with limit value as per DIN EN IEC 61340-5-1
Resistance to groundable point (R_{gp})	100	6.7×10^7	fulfilled
Body voltage positive	--	43.03	fulfilled
Body voltage negative	--	-8.26	fulfilled

This document only
applies to the named
product in its original state
and is valid for a period of
5 years from the current
date the document was
issued. The document can
be verified under
www.tested-device.com.

Detailed information and
parameters of the test
environment can be found
in the Fraunhofer IPA test
report.

The norms stated generally
refer to the version valid at
the time of the tests.

FO 2103-1219
Report No. first document

Stuttgart, April 1, 2021
Place, date of first document issued

FO 2606-1781
Report No. current document

Stuttgart, July 2, 2026
Place, current date

on behalf of


Dr.-Ing. Frank Bürger, head of business unit Testing and Certification



Fraunhofer
IPA