



SHERWIN-WILLIAMS UK Ltd  
Report No. SH 2602-1725  
Cleanroom (atmospheric)

# Cleanroom<sup>®</sup> Suitable Materials

Resutile HPS  
Biological Resistance:  
good

## FLOORING

### Single product Biological Resistance

### Qualification Certificate

We hereby certify that the material stated above, provided by

SHERWIN-WILLIAMS UK LIMITED  
Witney, United Kingdom

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number SH 2602-1725.

The biological resistance of the Resutile HPS (color: steel gray) regarding growth intensity was investigated in accordance with ISO 846 and classified with the following result:

| Biological resistance                   | Growth intensity | Classification |
|-----------------------------------------|------------------|----------------|
| Procedure A<br>(resistance to fungi)    | 1c               | good           |
| Procedure C<br>(resistance to bacteria) | 1                | good           |
| Overall result                          | good             |                |

The classification is based on a worst-case consideration of the Procedures A and C.

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under [www.tested-device.com](http://www.tested-device.com).

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

The norms stated generally refer to the version valid at the time of the tests.

SH 2602-1725  
Report No. first document  
--  
Report No. current document

Stuttgart, July 31, 2026  
Place, date of first document issued  
--  
Place, current date

on behalf of   
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification