IPA

valid until: February 13, 2030

Fraunhofer

TESTED® DEVICE

Siemens AG
SIMATIC ET 200clean
Report No. SI 2501-1588

Single product
Hygienic Design

DUPLICATE

Qualification Certificate

This is to certify that the product mentioned above, provided by

Siemens AG
Amberg, Germany

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number SI 2501-1588.

The peripheral system SIMATIC ET 200clean (color: white) is principally suitable for use in hygienic areas of food production and in pharmaceutical production up to the following GMP Class according to EU GMP Annex 1:

Suitability
up to GMP Class A / B

However, this recommendation only pertains to the operating utility when in a resting state. An overall assessment can only be made after its installation in the production environment.

SI 2501-1588	Stuttgart, February 13, 2025
Report No. first document	Place, date of first document issued
--	--
Report No. current document	Place, current date

on behalf of

Dr.-Ing. Frank Bürger, Project Manager Fraunhofer IPA

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Fraunhofer IPA