



# Cleanroom<sup>®</sup> Suitable Materials

**Gerflor**  
**Report No. GE 2105-1233**

**Mip. Biocontrol Clean**  
**H<sub>2</sub>O<sub>2</sub> Absorption/Desorption:**  
**non-absorptive**

## FLOORING & COATING

### Single product Hydrogen Peroxide Absorption/Desorption

### Qualification Certificate

We hereby certify that the material stated above, provided by

**Gerflor Mipolam GmbH**  
Troisdorf, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number GE 2105-1233.

The hydrogen peroxide absorption/desorption of Mipolam Biocontrol Clean (color: gray 5430) was investigated at the stated test parameters, providing the following test result according to VDI 2083 Part 20:

Ø k-value [min]	Standard deviation [min]	Classification
2.1	0	<b>non-absorptive</b>

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under [www.tested-device.com](http://www.tested-device.com).

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

GE 2105-1233  
Report No. first document

--  
Report No. current document

Stuttgart, September 20, 2021  
Place, date of first document issued

--  
Place, current date

on behalf of   
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA