



# Fraunhofer

## TESTED<sup>®</sup> DEVICE

Zumtobel Lighting GmbH  
INDUSTRY RECESSED  
**Report No. ZU 2503-1608**

Product series  
**Hygienic Design**

### Qualification Certificate

This is to certify that the product mentioned above, provided by

**Zumtobel Lighting GmbH**  
Dornbirn, Austria

has been awarded a Fraunhofer certificate TESTED DEVICE  
bearing the report number ZU 2503-1608.

The luminaire series INDUSTRY RECESSED is principally suitable  
for use in hygienic areas up to the following GMP Class according  
to EU GMP Annex 1:

Suitability
up to GMP Class C

However, this recommendation only pertains to the operating  
utility when in a resting state. An overall assessment can only be  
made after its installation in the production environment.

This document only  
applies to the named  
product in its original state  
and is valid for a period of  
5 years from the date the  
first document was issued.  
The document can be  
verified under  
[www.tested-device.com](http://www.tested-device.com).

Detailed information and  
parameters of the test  
environment can be found  
in the Fraunhofer IPA test  
report.

ZU 2503-1608  
Report No. first document

Stuttgart, May 26, 2025  
Place, date of first document issued

--  
Report No. current document

--  
Place, current date

on behalf of   
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification



**Fraunhofer**  
IPA