



valid until: October 2, 2030

Fraunhofer

TESTED[®]

DEVICE

ASSA ABLOY Entrance Systems
HS9130GAT

Report No. AS 2511-1686

Single product Hygienic Design

DUPPLICATED

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Qualification Certificate

This is to certify that the product mentioned above, provided by

ASSA ABLOY Entrance Systems
Lippstadt, Germany

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number AS 2511-1686.

The ASSA ABLOY High Speed Door HS9130GAT (color curtain: white) is principally suitable for use in hygienic areas up to the following GMP Class according to EU GMP Annex 1:

Suitability
up to GMP Class C

However, this only applies to the tested system in a resting state; an overall assessment of the manufacturing environment would need to be made after its installation.

AS 2511-1686
Report No. first document

Stuttgart, October 2, 2025
Place, date of first document issued

--
Report No. current document

--
Place, current date

on behalf of
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification



Fraunhofer
IPA