



valid until: June 12, 2029

# Fraunhofer

## TESTED<sup>®</sup> DEVICE

Regiolux GmbH  
ADAMP 600 8300 DALI  
**Report No. RE 2404-1517**

DUPLICATE

Statement of  
Qualification

Single product  
Particle Emission

# Statement of Qualification · Single product

**Customer**  
 Regiolux GmbH  
 Hellinger Strasse 3  
 97486 Königsberg  
 Germany

**Component tested**

Category: Cleanroom Facilities  
 Subcategory: Lighting Systems  
 Product name: ADAMP/600 LED 8300 940 DALI IP65  
 (manufacturing date: 3/2024; color: traffic white; article number: 6216 4026 670; charge number: PO03)

## Random sampling of particle emissions (airborne) at representative sites

Standards/Guidelines: ISO 14644-1, -14  
 The norms stated generally refer to the version valid at the time of the tests.

Test devices: Optical particle counter:  
 LasAir II 110 and LasAir III 110 with measuring ranges  $\geq 0.1 \mu\text{m}$ ,  $\geq 0.2 \mu\text{m}$ ,  $\geq 0.3 \mu\text{m}$ ,  $\geq 0.5 \mu\text{m}$ ,  $\geq 1.0 \mu\text{m}$  and  $\geq 5.0 \mu\text{m}$

Test environment parameters:

- Cleanroom Air Cleanliness Class (according to ISO 14644-1):..... ISO 1
- Airflow velocity:.....0.45 m/s
- Airflow pattern:..... vertical laminar flow
- Temperature: .....22 °C  $\pm$  0.5 °C
- Relative humidity: ..... 45 %  $\pm$  5 %

Test procedure parameters: The luminaire was subjected to stress as follows:

- Structure-borne noise: ..... approx. 50 Hz
- Oscillation velocity ( $\emptyset$ ):.....v = 1.2244 mm/s
- Oscillation acceleration ( $\emptyset$ ):.....a = 0.4744 m/s<sup>2</sup>
- Deflection of the system ( $\emptyset$ ):..... s = 0.0761 mm

## Test result / Classification

When operated under the specified test conditions, the luminaire ADAMP/600 LED 8300 940 DALI IP65 is suitable for use in cleanrooms fulfilling the specifications of the following Air Cleanliness Class according to ISO 14644-1:

Test parameter(s)	Air Cleanliness Class
Structure-borne noise = approx. 50 Hz	1
<b>Overall result</b>	

It should be noted that cleanrooms of class 1 to 5 according to ISO 14644-1 have a higher filter occupancy, which may restrict the use of panel lighting systems. Cleanrooms with a horizontal displacement flow form an exception to this.  
 The test result may be affected by the surrounding ceiling system, in particular the material pairing between lights and ceiling frames, as well as other mounting accessories. Particle emission behavior should be reassessed in each assembly situation.

Please note: Transport damages, incorrect installation, aging behavior, corrosion etc. can influence the test result.

The measuring devices used for the qualification tests are calibrated at regular intervals; their results can be traced back to national and international standards. In cases where no national standards exist, the test procedure implemented complies with the technical regulations and norms applicable at the time of the test. The relevant documentation can be viewed on request at any time.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Fraunhofer Institute for Manufacturing Engineering and Automation IPA

RE 2404-1517  
 Report No. first document

Stuttgart, June 12, 2024  
 Place, date of first document issued

Department of Ultraclean Technology and Micromanufacturing

--  
 Report No. current document

--  
 Place, current date

Nobelstrasse 12  
 70569 Stuttgart  
 Germany

on behalf of   
 Dr.-Ing. Frank Bürger, Project Manager Fraunhofer IPA