



valid until: February 6, 2031

Fraunhofer

TESTED[®] DEVICE

Ritterwand GmbH & Co. KG
TK+FK Series 498 UR 600 ges. RR
Report No. RI 2603-1734

Part product series
Hygienic Design

Qualification Certificate

This is to certify that the product mentioned above, provided by

Ritterwand GmbH & Co. KG
Nufingen, Germany

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number RI 2603-1734.

The lighting part product series TK+FK Series 498 UR 600 ges. RR (color: white (RAL 9010)); revisability: from below (UR)) is principally suitable for use in hygienic areas up to the following GMP Class according to EU GMP Annex 1:

Suitability
up to GMP Class C

However, this recommendation only pertains to the operating utility when in a resting state. An overall assessment can only be made after its installation in the manufacturing environment.

DUPLICATE

RI 2603-1734 Stuttgart, February 6, 2026
Report No. first document Place, date of first document issued

-- --
Report No. current document Place, current date

on behalf of 
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com. Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.