



GERFLOR CHINA
Report No. GE 2112-1287

Cleanroom[®] Suitable Materials

Mipolam Ambiance Ultra
Particle (vs. PA6 Nylon): ISO 3

FLOORING & COATING

Single product Particle Emission

Qualification Certificate

We hereby certify that the material stated above, provided by

Gerflor Floorings (China) Co., Ltd.
Changshu, China

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number GE 2112-1287.

The level of particulate contamination emitted during application of tribological stress on the material pairing specified lies within the permissible values of the corresponding Air Cleanliness Class in accordance with ISO 14644-1:

Material pairing and test		Suitable for Air Cleanliness Class (ISO 14644-1)
Mipolam Ambiance Ultra (0044 Slate Blue)	vs. PA6	ISO Class: 3
Reel-on-disc test normal force: 300N		

This document only applies to the named product in its original state and is valid for a period of 5 years from the current date the document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

GE 1711-961
Report No. first document
GE 2112-1287
Report No. current document

Stuttgart, November 10, 2017
Place, date of first document issued
Stuttgart, January 18, 2022
Place, current date

on behalf of 
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA