



Fraunhofer

**TESTED[®]
DEVICE**

Dräger Safety AG & Co. KGaA

Dräger X-plore 8700

Report No. DR 2207-1330

DUPLICATE

Statement of
Qualification

Single product
Particle Emission

Customer	Dräger Safety AG & Co. KGaA Revalstrasse 1 23560 Luebeck Germany
Component tested	
Category:	Working Place and Operator
Subcategory:	Work Equipment
Product name:	Dräger X-plore 8700 Powered Air Purifying Respirator with headpiece “hood” (manufacturing date, article and serial number: can be found in the Fraunhofer IPA test report; weight: 2.4 kg; battery: Dräger X-plore 8700 extended battery (EX); rated capacity/energy: 6.7 Ah/72 Wh; filter: X-plore 8000 filter P R SL; hood: X-plore 8000 premium hood, long (S/M))

Random sampling of particle emissions (airborne) at representative sites

Standards/Guidelines:	ISO 14644-1, -14 The norms stated generally refer to the version valid at the time of the tests.
Test devices:	Optical particle counter: LasAir II 110 and LasAir III 110 with measuring ranges $\geq 0.1 \mu\text{m}$, $\geq 0.2 \mu\text{m}$, $\geq 0.3 \mu\text{m}$, $\geq 0.5 \mu\text{m}$, $\geq 1.0 \mu\text{m}$ and $\geq 5.0 \mu\text{m}$
Test environment parameters:	<ul style="list-style-type: none">• Cleanroom Air Cleanliness Class (according to ISO 14644-1):..... ISO 1• Airflow velocity:.....0.45 m/s• Airflow pattern:..... vertical laminar flow• Temperature:22 °C ± 0.5 °C• Relative humidity: 45 % ± 5 %
Test procedure parameters:	<ul style="list-style-type: none">• Blower level:..... third stage• Hood:.....X-plore 8000 premium hood, long (S/M)• Volume flow:..... Q = 210 lpm• Maximum inward leakage:$Q_L \leq 0.2 \%$

Test result / Classification	When operated under the specified test conditions, the Dräger X-plore 8700 Powered Air Purifying Respirator with headpiece “hood” is suitable for use in cleanrooms fulfilling the specifications of the following Air Cleanliness Class according to ISO 14644-1:
------------------------------	---

Test parameter(s)	Air Cleanliness Class
Blower level: third fan stage; Hood: X-plore 8000 premium hood, long (S/M); Volume flow: Q = 210 lpm; Maximum inward leakage: $Q_L \leq 0.2 \%$	4
Overall result	

Please note: Transport damages, incorrect installation, aging behavior, etc.
can influence the test result.

The measuring devices used for the qualification tests are calibrated at regular intervals; their results can be traced back to national and international standards. In cases where no national standards exist, the test procedure implemented complies with the technical regulations and norms applicable at the time of the test. The relevant documentation can be viewed on request at any time.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Fraunhofer Institute for Manufacturing Engineering and Automation IPA	DR 2207-1330 Report No. first document	Stuttgart, August 26, 2022 Place, date of first document issued
Department of Ultraclean Technology and Micromanufacturing	-- Report No. current document	-- Place, current date
Nobelstrasse 12 70569 Stuttgart Germany	on behalf of Dr.-Ing. Frank Bürger, Project Manager Fraunhofer IPA	